128 N. SECOND STREET (970) 284-6931

LASALLE, CO 80645 FAX (970) 284-6983 TOWN HALL

June 16, 2022

2022 Water Sampling for Lead and Copper

The Town of LaSalle has completed its annual Lead and Copper sampling for the 2022 sampling year. The acceptable level for lead is 0.015 mg/L (15 ppb) and for copper is 1.3 mg/L. The 90th percentile results for the Town's Water were .001 mg/L for lead and <.2 for copper well below the allowable standards. For any further questions regarding the lead and copper results, please contact the Town Hall at 970-284-6931.

Barry Schaeffer, Public Works Director

COCOPHE

Lead Public Education Certificate of Delivery Form

** Submit this certification form and a copy of all public education materials**

Revision: 4/8/2016 Submit Online: wqcdcompliance.com/login (preferred); Fax: (303) 758-1398

WQCD-B2-Drinking Water CAS; 4300 Cherry Creek Drive South; Denver, CO 80246-1530

Section I Public Water System Information (Completed by Public Water Systems Only)	
PWSID: (0 Vo2466 System Name: TON OF LASAUE	
Contact Person: RLERY SOLAFFER Phone: 070 201 5625 Email: Delactore	ola salletown a
The water system named above hereby confirms that its lead public education materials have been distributed to	customers.
Comments:	
ALL SAMPLES TESTED WERE WELL BELOW LEAD ACTION ISIEL.	
System Authorized Signature Sully Starles Printed Name RARRY SCHAEGEE Date	10/14/27
Signature not required if submitted online.	6/19/22
Section II (Completed by Community Water Systems Only) - All Required Public Education Activities	Date
a) Public Education printed materials were sent to <u>all paying customers</u>	
b) Contacted local public health agencies directly by phone or in person and Public Education printed	
naterials were sent to local public health agencies (even if not located in service area)	
c) Public Education printed materials delivered to the following facilities.	
i) Public and private schools or school boards	
ii) Women Infants and Children (WIC) and Head Start Programs	
ii) Public and private hospitals and medical clinics	
v) Pediatricians	
/) Family planning clinics	
ri) Local welfare agencies	
d) "Good faith" efforts are required. Make a good faith effort to locate the following organizations with	
he service area and deliver public education materials.	
) Licensed childcare centers	
i) Public and private preschools	
ii) Obstetricians-Gynecologist and Midwives	
e) Include an informational notice in the materials distributed to the organizations in Steps B - D that	
encourages the distribution of the public educational materials to all of the potentially affected customers	
or users of the organizations.	
f) Conduct the following activities. For systems serving <=3,300, complete at least one activity.	
For systems serving >3,300, complete at least three activities.	
) Public Service Announcements	
i) Paid Advertisements	
ii) Display Information in Public Areas	1101-
v) Email to Customers	4111122
y) Public Meetings	
vi) Delivery to Every Household	4/17/22 4/29/22 4/17/22
ii) Direct material distribution to all multi-family homes and institutions	121/22
viii) Other methods approved by CDPHE: WEBSITE	6/17/22
g) Include informational statement on or in each <u>water bill, at least quarterly</u>	10
n) Submit press release to newspaper, television, <u>and</u> radio stations	
) For systems serving greater than 100,000 persons: Post material on water system's web site	
i) <u>Lead tap water results</u> sent to residences where samples were collected	
Section III (Completed by Non-Transient, Non-Community Water Systems Only) - Required Public	Date
a) Lead tap water results posted in public place or common area in each building	
b) Lead information posted in public place or common area in each building	
c) Distribute information pamphlets/brochures to individuals served by system	